



-RS-485 DEVICES CONNECTED IN A "DAISY CHAIN" TOPOLOGY
 -USE OF TWISTED PAIR SHILDED CABLE RECOMMENDED

-REMEMBER: Consider internal device connections (ie: between GND and Power Supply Negative Terminals)

ELKOR Technologies Inc.

DRAWN: PCK	TITLE: RS-485 Shielding	CODE:
CHECKED: CKK		
DATE: 2009/01/22	FILE: ..\RS-485_Shield.t4g	SHEET: 1 OF 1